



**RFP # 25-0006**

**Design and Build Blatnik Hall Fire Panel**

**ADDENDUM 2**

**Questions will be received until 3:00 PM, Wednesday, September 18, 2024**

**Proposals will be received until 10:00 AM, Wednesday, October 2, 2024**

**Proposals will be opened 10:05 AM, Wednesday, October 2, 2024**

The following vendors attended the pre-bid meeting and will be allowed to submit proposals.

Johnson Controls

ITS

SA Comunale

During the pre-bid tour, we were asked if vendors would be able to come back with copies of drawings for a more thorough tour.

**Yes, however, this will need to be coordinated through Patrick Kelly.**

During the pre-bid tour, WLU promised to provide a list of known equipment in Blatnik Hall. The information is as follows:

Device Type	Quantity	Location
Manual Pull Station	16	Hallway South (5), Hallway North (5) Women's Locker Room, Front Exit, Front Entrance, Gym, Boiler Room, North Side Exit – Bottom Floor
Fixed Temp Heat Detector	9	Gym (4) Boiler Room (2) Room Under Pool, Old Laundry Room, Pool Room – South End
Ion Smoke Detector	19	Hallway South (4), Hallway North (9), Front Entrance, Left Front Stairwell, Right Front Stairwell, Gym Front Stairwell, Gym Rear Stairwell, Room Under Pool

What follows are the best drawings we have available:







