



RFP # 25-0007

Addendum 2

Campus Door and Window Replacement

Questions will be received until 3:00 PM, Wednesday, November 27, 2024

Proposals will be received until 10:00 AM, Wednesday, December 11, 2024

Proposals will be opened 10:05 AM, Wednesday, December 11, 2024

**REQUEST FOR PROPOSALS # 25-0007
Addendum 2
Campus Door and Window Replacement**

The following questions were submitted by Lombardi Development

- 1. Myers door #1 currently has what appears to be a sliding window above for a transom look – how are we to price the window? I.E. leave, replace with slider, make transom, etc.**

We would like the selected vendor to leave a slider window.

- 2. Myers door 3 currently has a square glazed door lite – do you want new door to have lite?**

We would like the selected vendor to replace this door with a solid steel door

- 3. Boyd Hall doors 4,5,6,7,8 & 9 call for windows. Current doors have wire mesh in glazing are we to match existing or just insulated glazing?**

We would like Insulated glazing on these windows.

- 4. Krise hall doors 9 & 11 call for no windows. So new door slabs will be flush HM – What are we pricing for the transom windows above – insulated glazing or Insulated panels?**

Please price Insulated panels.

- 5. Is this project prevailing wage?**

No, this project was budgeted through a state grant with no requirement to pay a prevailing wage.